

Sponsor: Valor Zhu Wellmien (Suzhou) Imp. & Exp. Trading Co., Ltd 18-1508, Building B, Wanda Sqaure No 3188 Renmin Rd Suzhou, Jiangsu, 215000

Bacterial Filtration Efficiency (BFE) Final Report

Test Article: 2020 Wellmien Surgical mask ASTM F2100-19 Level 2

Purchase Order: WM200715 Study Number: 1324350-S01 Study Received Date: 24 Jul 2020

Testing Facility: Nelson Laboratories, LLC

6280 S. Redwood Rd.

Salt Lake City, UT 84123 U.S.A.

Test Procedure(s): Standard Test Protocol (STP) Number: STP0004 Rev 18

Deviation(s): None

Summary: The BFE test is performed to determine the filtration efficiency of test articles by comparing the bacterial control counts upstream of the test article to the bacterial counts downstream. A suspension of *Staphylococcus aureus* was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and fixed air pressure. The challenge delivery was maintained at $1.7 - 3.0 \times 10^3$ colony forming units (CFU) with a mean particle size (MPS) of $3.0 \pm 0.3 \mu m$. The aerosols were drawn through a six-stage, viable particle, Andersen sampler for collection. This test method complies with ASTM F2101-19 and EN 14683:2019, Annex B.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.

Test Side: Inside BFE Test Area: ~40 cm²

BFE Flow Rate: 28.3 Liters per minute (L/min)

Conditioning Parameters: 85 ± 5% relative humidity (RH) and 21 ± 5°C for a minimum of 4 hours

Test Article Dimensions: ~170 mm x ~165 mm Positive Control Average: 1.8 x 10³ CFU

Negative Monitor Count: <1 CFU

MPS: 2.9 µm





James Luskin electronically approved

Study Director

James Luskin

25 Aug 2020 15:26 (+00:00) Study Completion Date and Time

801-290-7500

nelsonlabs.com

sales@nelsonlabs.com

myf

FRT0004-0001 Rev 22 Page 1 of 2



Results:

Test Article Number	Percent BFE (%)
1	>99.9 ^a
2	>99.9 ^a
3	>99.9 ^a
4	>99.9 ^a
5	>99.9 ^a

^a There were no detected colonies on any of the Andersen sampler plates for this test article.

The filtration efficiency percentages were calculated using the following equation:

$$\% BFE = \frac{C-T}{C} \times 100$$

www.wellmien.com

WAN WE HUIGH COM

www.wellkrien.com

C = Positive control average

T = Plate count total recovered downstream of the test article White Wellkrife H. Colff Note: The plate count total is available upon request

MAN MEHRIER COM

NAM NE HUIEN COLL

MAN WE HUIL

MAN ME HUIEU COLU